



Nava Raipur Atal Nagar Vikas Pradhikaran

Paryavas Bhawan, North Block, Sector-19, Nava Raipur, Atal Nagar, Dist.-Raipur (C.G.) - 492002

Office Ph No. 0771-2512500, Fax No. 0771-2512400

Email: ceo.anvp-cg@gov.in, Web Site – www.navaraipuratalnagar.com

No. 07

/4(3)/1/26/EE(C-III)CE/NRANVP/2025/Nava Raipur, Atal Nagar,

dated: 10/01/2025

SAFE DRINKING WATER CERTIFICATE

-----//-----

It is certified that an inspection team headed by Mr. Anil Kumar Yadav, Assistant Engineer (C-III), from Nava Raipur Atal Nagar Vikas Pradhikaran inspected the Drinking Water Facilities of Bharat Mata Sec. School, Sector-26 on 10/01/2025 and found that the Bharat Mata Sec. School, Sector-26 has safe Drinking Water Facilities for the students and members of staff of the institution.

(Encl :- Water Test Report – 1)

Executive Engineer (C-II)

Nava Raipur Atal Nagar Vikas Pradhikaran

Nava Raipur, Atal Nagar (C.G.)

Sample Collect from Bharat Mata School at Sector -26 Naya Raipur Atal Nagar (C.G.)						
Sr. No.	Date	Parameter	Unit's	water sample	IS -10500-2012	
					requirement Acceptable Limit	permissible Limit
1	10-01-25	pH	—	7.51	6.5 - 8.5	No relaxation
2		Electric Conductivity	μS/CM	154.4	—	1000
3		Turbidity	NTU	1.90	1	5
4		total dissolved solid	mg/l	115.5	500	2000
5		total Hardness	mg/l	70	200	600
6		total alkalinity	mg/l	64	200	600



[Handwritten Signature]
 10/1/2025
 Assistant Engineer (Civil-III)
 Nava Raipur Atal Nagar Vikas Pradhikaran
 Nava Raipur Atal Nagar (C.G.)

OFFICE , BLOCK MEDICAL & HEALTH OFFICER

COMMUNITY HEALTH CENTRE ARANG, DIST. RAIPUR

Date 06-03-2025

HEALTH AND SANITARY CERTIFICATE

I hereby declare that, I inspected Bharat Mata Sit. Sec. School, Rakhi, Sector-26, Naya Raipur. I find the classrooms are properly ventilated. The school campus and the surroundings are comfortable and conducive for children and staff. The washrooms are sufficient and clean with proper water source. There is sufficient source of drinking water available for them.

I certify that the health and sanitation at Bharat Mata Sr. Sec. School, Rakhi, Sector-26 Naya Raipur are satisfactory.


Block Medical Officer
Block Medical Officer
Community Health Centre Arang

Community Health Centre Arang