



नवा रायपुर
अटल नगर

Nava Raipur Atal Nagar Vikas Pradhikaran

Paryavas Bhawan, North Block, Sector-19, Nava Raipur, Atal Nagar, Dist.-Raipur (C.G.) - 492002

Office Ph No. 0771-2512500, Fax No. 0771-2512400

Email: ceo.anvp-cg@gov.in, Web Site – www.navaraipuratalnagar.com

No. 79 /4(3)/1/76/EE(C-I)CE/NRANVP/2026/Nava Raipur Atal Nagar, dated: 20/03/2026

SAFE DRINKING WATER CERTIFICATE

-----//-----

It is certified that an inspection team headed by Mr. Anil Kumar Yadav, Assistant Engineer (C-III), from Nava Raipur Atal Nagar Vikas Pradhikaran inspected the Drinking Water Facilities of Bharat Mata Sec. School, Sector-26 on 26/02/2026 and found that the Bharat Mata Sec. School, Sector-26 has safe Drinking Water Facilities for the students and members of staff of the institution.

(Encl :- Water Test Report – 1)


Executive Engineer (C-I)

Nava Raipur Atal Nagar Vikas Pradhikaran
Nava Raipur Atal Nagar (C.G.)



Sample Collect From Sector :- 26 ,Bharat Mata SR. SEC. School ,Naya Raipur Atal Nagar (C.G.)

Sr. No.	Date	Parameter	Unit's	Before Tank , Water Sample	IS -10500-2012	
					Requirment Acceptable Limit	Permissible Limit
1	26-02-26	pH	—	7.55	6.5 - 8.5	No Relaxation
2		Electric Conductivity	μS/CM	141.10	—	1000
3		Turbidity	NTU	0.94	1	5
4		Total Disolved Solid	mg/l	92	500	2000
5		Total Hardness	mg/l	76	200	600
6		Total Alkalinity	mg/l	55	200	600
7		E. Coli	CFU/100ml	NIL		—




 Lab Chemist



 Plant Manager





 20/3/2016